

MIAMI UNIVERSITY
OFFICE OF FACILITIES CONTRACTING
OXFORD, OHIO 45056

ADDENDUM #2

PATTERSON PLACE RENOVATION 2019

Please note the following items which become part and parcel of the Contract Documents and must be included in your Bid.

ITEM 1: BID OPENING DATE EXTENDED TO 2:30PM MAY 13, 2019:

Per Section 3.3 of the Instructions to Bidders, due to the issuance of the A/E's Addendum #2, which contains clarifications to the Contract Documents, the Bid Opening is now extended to **2:30PM on May 13, 2019.**

ITEM 2: A/E'S ADDENDUM #2:

The A/E's Addendum #2 is a one (1) page document which clarifies the Electrical and Mechanical Specifications so as to state that the existing HVAC system is **NOT** part of a Building Automation System (BAS) and that the General Contractor shall be responsible for the electrical requirements for the fan and for the line voltage from the thermostat for the fin tube.

NOTE: THIS ADDENDUM ALONG WITH A LIST OF CURRENT PLAN HOLDERS IS AVAILABLE ON THE FCO WEBSITE AT www.pfd.miamioh.edu/fco

Please note receipt of Addendum #2 on the Bid Form.

Elizabeth Davidson
Director, Facilities Contracting Office

May 3, 2019