

MIAMI UNIVERSITY PATTERSON PLACE RENOVATION 2019

325 S. PATTERSON AVE.
MIAMI UNIVERSITY
OXFORD, OH 45056
COMMISSION NUMBER 1863

ADDENDUM #02

May 3, 2019

This addendum is a modification of the Contract Documents for this project. It is to be considered in the Proposals and covers additions to or changes in the Contract Documents as follows:

This addendum consists of the following:

- Addendum document consisting of one (1) page in 8.5"X11" format

MECHANICAL NOTE

ITEM #1 CLARIFICATION:

The existing HVAC system is not part of a Building Automation System (BAS).

ELECTRICAL NOTE

ITEM #2 CLARIFICATION:

The electrical contractor is responsible for the electrical requirements for the fan and also responsible for the line voltage from the thermostat for the fin tube.

END OF ADDENDUM #02